



LICHENS ENVIRONMENT PVT LTD.

ENVIRONMENT CONSULTANT & MANUFACTURERS OF RO, DM, PORTABLE STP,
School no. 6 ETP, CETP, LANDSCAPING, RAIN WATER HARVESTING


Sr.no.	Name of Test	Unit	Result	Limit (Min-Max)
1	Odour	-----	Odourless	Agreeable
2	pH value	-----	8.19	6.5-8.5
3	Total Dissolve Solids	Mg/L	251	Max 1500
4	Turbidity	NTU	1.75	Max 10
5	E-coli	(cfu)	0	0

AEIC Jr. Collage

Sr.no.	Name of Test	Unit	Result	Limit (Min-Max)
1	Odour	-----	Odourless	Agreeable
2	pH value	-----	8.07	6.5-8.5
3	Total Dissolve Solids	Mg/L	296	Max 1500
4	Turbidity	NTU	2.06	Max 10
5	E-coli	(cfu)	0	0

Education Society

Sr.no.	Name of Test	Unit	Result	Limit (Min-Max)
1	Odour	-----	Odourless	Agreeable
2	pH value	-----	8.28	6.5-8.5
3	Total Dissolve Solids	Mg/L	326	Max 1500
4	Turbidity	NTU	1.29	Max 10
5	E-coli	(cfu)	0	0

Checked by :  27/05/2023

Lab Assistance

(M/S Lichens Environment Pvt. Ltd)
Regd. Office : Sangeet CHSL - 12, B-43, Jeeval Park,
Bhayander (E), Mumbai - 401 105.
Cell : +919821844466, +919323291420
Email : admin@lichens.in



Branch Office : 1st Flr., Dairy Farm, 91, Masoodpur,
Vasant Kunj, New Delhi - 110 070.
Cell : +919870333525
Email : lichensindia@hotmail.com

परमाणु ऊर्जा विभाग
accounts@lichens.in

नि. से. सं. प्र. नि. / DCSEM

अनुशक्तिनगर / Anushaktinagar

www.lichens.in



Scanned with OKEN Scanner